



Daily Report

Date: _____
 Customer Name: _____
 Job Name: _____
 Job Address: _____
 Contact Name: _____
 Contact Number: _____
 Contacts Email: _____

Operator: **Emmett Winston, Sr**
 PM's Name: _____
 M's Number: _____
 PM's Email: _____
 Other: _____

| Image | Floor | Code | Room # | Comments |
|-------|-------|------|--------|--|
| | | | | The client has three areas that he needs me to GPR for core drilling 3 or 4" holes. Per the client this is a PT Cable slab. |
| 1 | 3 | 3 | n/a | 48"x46" Floor scan. The client wants to drill a 4" hole at K8h. I marked out the following cables on B, Eh, Hh, Jh and 1" before L. I also marked out a conduit running from A10 to J10 to M9h. |
| 2 | 3 | 3 | n/a | 48"x48" Floor scan. The client wants to drill a 3" hole at 1" after G at 3. I marked out the following cables; lines B, Eh, Hh, Jh and L. |
| 3 | 3 | 3 | n/a | 48"x32" Floor scan. The client wants to drill a 3" hole outside of the scan area above the M line inside of a wall. I marked out the following cables; lines 2, 3h and 6h. I am keeping the client out of 1-4+1". |
| 4 | 3 | 3 | n/a | 46"x48" Floor scan. The client wants to drill a 3" hole outside of the scan area above the M line inside of a wall. I am not seeing the bottom of the slab in this scan. I viewed the ceiling and there is a beam but the client thought that he was outside of the beam area. I advised that he is in the beam. I reviewed with Ed Manning and he also confirmed that we are not see the bottom and that we are in a beam area. |
| 5 | 3 | 3 | n/a | 48"x48" Floor scan. The client requested that I perform another scan to the left of scan #4 to see if he would be out of the beam. The client will be drilling inside of a wall on the I line from 5h 10h to . There is a cable running from Bh1 to C13 and between Gh to J. The beam starts at 1" before 11 to 13. There is also a vertical cable running on line 8. |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |